



Must have total of 5 valves

Ball or gate valves on each side of meter (typical)

Angle valve with A34 adaptor

Incoming water service

Secondary meter

For pressure regulated areas install regulator immediately after angle valve but before tee

Outside water use only charges

Inside water/sewer use charges

Water Meter (Demand) for use in areas where water meters are not installed. The secondary water meter shall allow for the future use of water for irrigation, etc. for a maximum period of 10 years. The meter shall be installed in a location which is accessible for inspection and repair.